

Certificate of Product Ratings

AHRI Certified Reference Number: 2120692

Date: 1/19/2015

†Status: Active

Product: Commercial Boiler Heating Equipment

Model Number: N-700

Manufacturer: HARSCO INDUSTRIAL, PATTERSON-KELLEY

Trade/Brand name: P-K THERMIFIC

Rated as follows in accordance with Department of Energy (DOE) Boiler test procedures as published in the latest edition of the Code of Federal Regulations, 10 CFR Part 431 and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Combustion Efficiency:	-
Thermal Efficiency:	85.0 %

The following data is for reference only and is not certified by AHRI:

Material:	Copper
Location:	Indoor
Fuel Type:	Natural Gas, Propane Gas
Input:	700.0 MBTUH
Gross Output:	595 MBTUH
Ignition Type:	Intermittent/Electronic Ignition
Draft Type:	Pressure Fired
CO2:	7.5
Net Ratings - Water:	517.00 MBTUH

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.: 130661760431410610

Certificate of Product Ratings

AHRI Certified Reference Number: 2120691

Date: 1/19/2015

†Status: Active

Product: Commercial Boiler Heating Equipment

Model Number: N-1000

Manufacturer: HARSCO INDUSTRIAL, PATTERSON-KELLEY

Trade/Brand name: P-K THERMIFIC

Rated as follows in accordance with Department of Energy (DOE) Boiler test procedures as published in the latest edition of the Code of Federal Regulations, 10 CFR Part 431 and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Combustion Efficiency:	-
Thermal Efficiency:	85.0 %

The following data is for reference only and is not certified by AHRI:

Material:	Copper
Location:	Indoor
Fuel Type:	Natural Gas, Propane Gas
Input:	1000.0 MBTUH
Gross Output:	850 MBTUH
Ignition Type:	Intermittent/Electronic Ignition
Draft Type:	Pressure Fired
CO2:	7.5
Net Ratings - Water:	739.00 MBTUH

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.: 130661760051540870

Certificate of Product Ratings

AHRI Certified Reference Number: 2120701

Date: 1/19/2015

†Status: Active

Product: Commercial Boiler Heating Equipment

Model Number: N-1500-2

Manufacturer: HARSCO INDUSTRIAL, PATTERSON-KELLEY

Trade/Brand name: P-K THERMIFIC

Rated as follows in accordance with Department of Energy (DOE) Boiler test procedures as published in the latest edition of the Code of Federal Regulations, 10 CFR Part 431 and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Combustion Efficiency:	-
Thermal Efficiency:	85.0 %

The following data is for reference only and is not certified by AHRI:

Material:	Copper
Location:	Indoor
Fuel Type:	Natural Gas, Propane Gas
Input:	1500.0 MBTUH
Gross Output:	1275 MBTUH
Ignition Type:	Intermittent/Electronic Ignition
Draft Type:	Pressure Fired
CO2:	7.5
Net Ratings - Water:	1109.00 MBTUH

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.: 130661760135471022

Certificate of Product Ratings

AHRI Certified Reference Number: 2120702

Date: 1/19/2015

†Status: Active

Product: Commercial Boiler Heating Equipment

Model Number: N-1700-2

Manufacturer: HARSCO INDUSTRIAL, PATTERSON-KELLEY

Trade/Brand name: P-K THERMIFIC

Rated as follows in accordance with Department of Energy (DOE) Boiler test procedures as published in the latest edition of the Code of Federal Regulations, 10 CFR Part 431 and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Combustion Efficiency:	-
Thermal Efficiency:	85.0 %

The following data is for reference only and is not certified by AHRI:

Material:	Copper
Location:	Indoor
Fuel Type:	Natural Gas, Propane Gas
Input:	1700.0 MBTUH
Gross Output:	1445 MBTUH
Ignition Type:	Intermittent/Electronic Ignition
Draft Type:	Pressure Fired
CO2:	7.5
Net Ratings - Water:	1257.00 MBTUH

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.: 130661760190228426

Certificate of Product Ratings

AHRI Certified Reference Number: 2120703

Date: 1/19/2015

†Status: Active

Product: Commercial Boiler Heating Equipment

Model Number: N-2000-2

Manufacturer: HARSCO INDUSTRIAL, PATTERSON-KELLEY

Trade/Brand name: P-K THERMIFIC

Rated as follows in accordance with Department of Energy (DOE) Boiler test procedures as published in the latest edition of the Code of Federal Regulations, 10 CFR Part 431 and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Combustion Efficiency:	-
Thermal Efficiency:	85.0 %

The following data is for reference only and is not certified by AHRI:

Material:	Copper
Location:	Indoor
Fuel Type:	Natural Gas, Propane Gas
Input:	2000.0 MBTUH
Gross Output:	1700 MBTUH
Ignition Type:	Intermittent/Electronic Ignition
Draft Type:	Pressure Fired
CO ₂ :	7.5
Net Ratings - Water:	1478.00 MBTUH

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.: 130661760243425790