

### PATTERSON KELLEY

### SOLIS 3M CONDENSING BOILER

DES. J. ROBERSON

JOB NO. 11-2107

DATE 3/17/21


SHEET

1

OF 2 SHEETS

SEISMIC ANCHORAGE

SLAB ON GRADE



T<sub>u</sub> = 2958 LB/BOLT (MAX)

V<sub>u</sub> = 1521 LB/BOLT (MAX)

**NOTES:**

1. FORCES ARE DETERMINED PER 2019 CALIFORNIA BUILDING CODE AND ASCE 7-16.

STRENGTH DESIGN IS USED. (S<sub>bs</sub> = 2.20, a<sub>p</sub> = 1.0, l<sub>p</sub> = 1.5, R<sub>p</sub> = 2.5,  $\Omega_o$  = 2.0, z/h = 0)

HORIZONTAL FORCE (E<sub>h</sub>) = 0.99 W<sub>p</sub>

HORIZONTAL FORCE (E<sub>mh</sub>) = 1.98 W<sub>p</sub> (FOR CONCRETE ANCHORAGE)

VERTICAL FORCE (E<sub>v</sub>) = 0.44 W<sub>p</sub>

2. CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THESE CALCULATIONS ENCOMPASS ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.

3. STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL VERIFY ALL CONDITIONS AND PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



### PATTERSON KELLEY

DES. J. ROBERSON

SHEET

2

### SOLIS 3M CONDENSING BOILER


JOB NO. 11-2107

DATE 3/17/21

OF 2 SHEETS

SEISMIC ANCHORAGE

SLAB ON GRADE



LOADS: PER 2019 CALIFORNIA BUILDING CODE AND ASCE 7-16.

STRENGTH DESIGN IS USED ( $S_Ds = 2.20$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 2.5$ ,  $\Omega_o = 2.0$ ,  $z/h = 0$ )

WEIGHT = 3500 LB

HORIZONTAL FORCE ( $E_{mh}$ ) =  $1.98 W_p = 6930$  LB

VERTICAL FORCE ( $E_v$ ) =  $0.44 W_p = 1540$  LB

BOLT FORCES:

BOLT SPECS: 3/4"φ HILTI KB-TZ ( $h_{ef} = 3.75"$ )

EDGE DISTANCE = 27" MIN;

$\phi T = 0.75 \phi N_n = 3296$  LB/BOLT (TENSION)

$\phi V = \phi V_n = 7634$  LB/BOLT (SHEAR)

TENSION (T)

$$T_u \text{ MAXIMUM} = \left[ \frac{6930\#(39.9'')(37.7'')}{2 \text{ BOLTS } (37.8'')(55.6'')} \times (0.3) \right] + \frac{6930\#(39.9'')}{2 \text{ BOLTS } (55.6'')} - \frac{(3500\#(0.9) - 1540\#)(37.7'')}{4 \text{ BOLTS } (55.6'')} = 2958 \text{ LB/BOLT (MAX)}$$

(HORIZ - SIDE TO SIDE)                      (HORIZ - FRONT TO BACK)                      (WEIGHT (0.9) -  $E_v$ )

SHEAR (V)

$$V_u \text{ MAXIMUM} = \left[ \frac{6930\#}{6 \text{ BOLTS}} \times (0.3) \right] + \frac{6930\#(37.7'')}{4 \text{ BOLTS } (55.6'')} = 1521 \text{ LB/BOLT (MAX)}$$

UNITY CHECK:

$$\left( \frac{T_u}{\phi T} \right) + \left( \frac{V_u}{\phi V} \right) \leq 1.2 \quad \left( \frac{2958}{3296} \right) + \left( \frac{1521}{7634} \right) = 1.10 \leq 1.2 \quad \therefore \text{O.K.}$$

## PATTERSON KELLEY

### SOLIS 3M CONDENSING BOILER

DES. **J. ROBERSON**

JOB NO. **11-2107**

DATE **3/17/21**


SHEET

**1**

OF **2** SHEETS

SEISMIC ANCHORAGE

UPPER FLOOR



$T_u = 2448 \text{ LB/BOLT (MAX)}$   
 $V_u = 1275 \text{ LB/BOLT (MAX)}$

**NOTES:**

1. **FORCES ARE DETERMINED PER 2019 CALIFORNIA BUILDING CODE AND ASCE 7-16.**

STRENGTH DESIGN IS USED. ( $S_{bs} = 2.30$ ,  $a_p = 1.0$ ,  $l_p = 1.5$ ,  $R_p = 2.5$ ,  $z/h \leq 1$ )

HORIZONTAL FORCE ( $E_h$ ) =  $1.66 W_p$

VERTICAL FORCE ( $E_v$ ) =  $0.46 W_p$

2. CENTER OF GRAVITY (C.G.) AND WEIGHT ARE THE GOVERNING PARAMETERS FOR DESIGN. THESE CALCULATIONS ENCOMPASS ALL WEIGHTS UP TO THE MAXIMUM WEIGHT SHOWN.

3. STRUCTURAL ENGINEER OF RECORD FOR THE BUILDING SHALL VERIFY ALL CONDITIONS AND PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



### PATTERSON KELLEY

DES. J. ROBERSON

SHEET

2

### SOLIS 3M CONDENSING BOILER


JOB NO. 11-2107

DATE 3/17/21

OF 2 SHEETS

SEISMIC ANCHORAGE

UPPER FLOOR



LOADS: PER 2019 CALIFORNIA BUILDING CODE AND ASCE 7-16.

STRENGTH DESIGN IS USED ( $S_{ds} = 2.30$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 2.5$ ,  $z/h \leq 1$ )

WEIGHT = 3500 LB

HORIZONTAL FORCE ( $E_h$ ) =  $1.66 W_p = 5810$  LB

VERTICAL FORCE ( $E_v$ ) =  $0.46 W_p = 1610$  LB

BOLT FORCES:

BOLT SPECS: 3/4"φ (A36) THREADED ROD

φT = 14,420 LB/BOLT (TENSION)

φV = 7691 LB/BOLT (SHEAR)

TENSION (T)

$$T_u \text{ MAXIMUM} = \left[ \frac{5810\#(39.9'')(37.7'')}{2 \text{ BOLTS } (37.8'')(55.6'')} \times (0.3) \right] + \frac{5810\#(39.9'')}{2 \text{ BOLTS } (55.6'')} - \frac{(3500\#(0.9) - 1610\#)(37.7'')}{4 \text{ BOLTS } (55.6'')} = 2448 \text{ LB/BOLT (MAX)}$$

(HORIZ - SIDE TO SIDE)                      (HORIZ - FRONT TO BACK)                      (WEIGHT (0.9) -  $E_v$ )

SHEAR (V)

$$V_u \text{ MAXIMUM} = \left[ \frac{5810\#}{6 \text{ BOLTS}} \times (0.3) \right] + \frac{5810\#(37.7'')}{4 \text{ BOLTS } (55.6'')} = 1275 \text{ LB/BOLT (MAX)}$$