

### PATTERSON-KELLEY

### SOLIS 1500-2000 BOILER

DES. J. ROBERSON

JOB NO. 11-2315

DATE 7/5/23


SHEET

1

OF 2 SHEETS

SEISMIC ANCHORAGE

SLAB ON GRADE



$T_u$  = 1427 LB/BOLT (MAX)

$V_u$  = 605 LB/BOLT (MAX)

#### NOTES:

- FORCES ARE DETERMINED PER 2022 CALIFORNIA BUILDING CODE AND ASCE 7-16. STRENGTH DESIGN IS USED. (EXAMPLE:  $S_{ds} = 2.20$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 2.5$ ,  $\Omega_o = 2.0$ ,  $z/h = 0$ )

HORIZONTAL FORCE ( $E_h$ ) =  $0.99 W_p$

HORIZONTAL FORCE ( $E_{mh}$ ) =  $1.98 W_p$  (FOR CONCRETE ANCHORAGE)

VERTICAL FORCE ( $E_v$ ) =  $0.44 W_p$

- THIS CALCULATION ENCOMPASSES WEIGHTS AND VERTICAL C.G. POSITIONS NOT EXCEEDING VALUES SHOWN.
- THIS CALCULATION WAS PREPARED WITHOUT KNOWLEDGE OF ANY SITE CONDITION. COMPATIBILITY FOR USE WITH A SITE SHALL BE EVALUATED BY THE STRUCTURAL ENGINEER OF RECORD OF THE INSTALLATION (SEOR). USE REQUIRES APPROVAL BY THE SEOR.
- STRUCTURAL ENGINEER OF RECORD FOR THE INSTALLATION SHALL VERIFY ALL CONDITIONS, EVALUATE INTERACTION WITH ADJACENT EQUIPMENT AND ANCHORS, AND PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



### PATTERSON-KELLEY

### SOLIS 1500-2000 BOILER

DES. J. ROBERSON

JOB NO. 11-2315

DATE 7/5/23


SHEET

2

OF 2 SHEETS

SEISMIC ANCHORAGE

SLAB ON GRADE



SIDE ELEVATION

**LOADS:**

WEIGHT ( $W_p$ ) = 2834 LB  
 HORIZONTAL FORCE ( $E_{mh}$ ) = 1.98  $W_p$  = 5611 LB  
 VERTICAL FORCE ( $E_v$ ) = 0.44  $W_p$  = 1247 LB

ANCHOR SPEC: 5/8"  $\phi$  HILTI KB-TZ2 (CS); (hef = 3.25")  
 SPACING = 3" MIN  
 EDGE DISTANCE = 32" MIN;  
 $\phi T = 0.75 \phi N_n$  = 2148 LB/ANCHOR (TENSION)  
 $\phi V = \phi V_n$  = 6169 LB/ANCHOR (SHEAR)

**ANCHOR FORCES:**

TENSION (T)

$$T_u \text{ MAXIMUM} = \left[ \frac{5611\#(38.9'')(29.1'')}{4 \text{ BOLTS } (37.6'')(43.7'')} \times (0.3) \right] + \frac{5611\#(38.9'')}{4 \text{ BOLTS } (43.7'')} - \frac{(2834\#(0.9) - 1247\#(29.1''))}{8 \text{ BOLTS } (43.7'')} = 1427 \text{ LB/BOLT (MAX)}$$

( HORIZ - FRONT TO BACK )                      ( HORIZ - SIDE TO SIDE )                      ( WEIGHT(0.9) -  $E_v$  )

SHEAR (V)

$$V_u \text{ MAXIMUM} = \left[ \frac{5611\#}{12 \text{ BOLTS}} \times (0.3) \right] + \frac{5611\#(29.1'')}{8 \text{ BOLTS } (43.7'')} = 605 \text{ LB/BOLT (MAX)}$$

**INTERACTION:**

$$\left( \frac{T_u}{\phi T} \right) + \left( \frac{V_u}{\phi V} \right) \leq 1.2 \left( \frac{1427}{2148} \right) + \left( \frac{605}{6169} \right) = 0.76 \leq 1.2 \therefore \text{O.K.}$$

### PATTERSON-KELLEY

### SOLIS 1500-2000 BOILER

DES. J. ROBERSON

JOB NO. 11-2315

DATE 7/5/23


SHEET

1

OF 2 SHEETS

SEISMIC ANCHORAGE

UPPER FLOOR



$T_u = 1184 \text{ LB/BOLT (MAX)}$   
 $V_u = 507 \text{ LB/BOLT (MAX)}$

**NOTES:**

1. FORCES ARE DETERMINED PER 2022 CALIFORNIA BUILDING CODE AND ASCE 7-16. STRENGTH DESIGN IS USED. (EXAMPLE:  $S_{ds} = 2.30$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 2.5$ ,  $z/h \leq 1$ )

HORIZONTAL FORCE ( $E_h$ ) =  $1.66 W_p$

VERTICAL FORCE ( $E_v$ ) =  $0.46 W_p$

2. THIS CALCULATION ENCOMPASSES WEIGHTS AND VERTICAL C.G. POSITIONS NOT EXCEEDING VALUES SHOWN.

3. THIS CALCULATION WAS PREPARED WITHOUT KNOWLEDGE OF ANY SITE CONDITION. COMPATIBILITY FOR USE WITH A SITE SHALL BE EVALUATED BY THE STRUCTURAL ENGINEER OF RECORD OF THE INSTALLATION (SEOR). USE REQUIRES APPROVAL BY THE SEOR.

4. STRUCTURAL ENGINEER OF RECORD FOR THE INSTALLATION SHALL VERIFY ALL CONDITIONS, EVALUATE INTERACTION WITH ADJACENT EQUIPMENT AND ANCHORS, AND PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



### PATTERSON-KELLEY

### SOLIS 1500-2000 BOILER

DES. J. ROBERSON

JOB NO. 11-2315

DATE 7/5/23


SHEET

2

OF 2 SHEETS

SEISMIC ANCHORAGE

UPPER FLOOR



SIDE ELEVATION

LOADS:

WEIGHT (W<sub>p</sub>) = 2834 LB  
 HORIZONTAL FORCE (E<sub>h</sub>) = 1.66 W<sub>p</sub> = 4704 LB  
 VERTICAL FORCE (E<sub>v</sub>) = 0.46 W<sub>p</sub> = 1304 LB

ANCHOR SPECS: 5/8"φ (A307) THREADED ROD

φT= 9870 LB/BOLT (TENSION)  
 φV= 5890 LB/BOLT (SHEAR)

ANCHOR FORCES:

TENSION (T)

$$T_U \text{ MAXIMUM} = \left[ \frac{4704\#(38.9\")(29.1\"){}}{4 \text{ BOLTS } (37.6\")(43.7\")} \times (0.3) \right] + \frac{4704\#(38.9\"){}}{4 \text{ BOLTS } (43.7\")} - \frac{(2834\#(0.9) - 1304\#(29.1\"))}{8 \text{ BOLTS } (43.7\")} = 1184 \text{ LB/BOLT (MAX)}$$

( HORIZ - FRONT TO BACK )                      ( HORIZ - SIDE TO SIDE )                      ( WEIGHT(0.9) - E<sub>v</sub> )

SHEAR (V)

$$V_U \text{ MAXIMUM} = \left[ \frac{4704\#}{12 \text{ BOLTS}} \times (0.3) \right] + \frac{4704\#(29.1\"){}}{8 \text{ BOLTS } (43.7\")} = 507 \text{ LB/BOLT (MAX)}$$

### PATTERSON-KELLEY

### SOLIS 1500-2000 BOILER

DES. J. ROBERSON

JOB NO. 11-2315

DATE 7/5/23



SHEET

1

OF 1 SHEETS


SEISMIC ANCHORAGE

BRACKET DETAILS




TOP


ISOMETRIC



FRONT



SECTION "A"- "A"



### FLOOR ANCHOR BRACKET