

### PATTERSON-KELLEY

### STORM 650/800/1000 COMMERCIAL BOILERS

DES. J. ROBERSON

JOB NO. 11-2506

DATE 5/23/25


SHEET

1

OF 2 SHEETS

SEISMIC ANCHORAGE

SLAB ON GRADE



#### NOTES:

- FORCES ARE DETERMINED PER 2022 CALIFORNIA BUILDING CODE AND ASCE 7-16. STRENGTH DESIGN IS USED. (EXAMPLE: S<sub>DS</sub> = 2.30, a<sub>p</sub> = 1.0, I<sub>p</sub> = 1.5, R<sub>p</sub> = 2.5,  $\Omega_0$  = 2.0, z/h = 0)

$$\begin{aligned} \text{HORIZONTAL FORCE (E}_h) &= 1.035 W_p \\ \text{HORIZONTAL FORCE (E}_{mh}) &= 2.07 W_p \text{ (FOR CONCRETE ANCHORAGE)} \\ \text{VERTICAL FORCE (E}_v) &= 0.46 W_p \end{aligned}$$

- THIS CALCULATION ENCOMPASSES WEIGHTS AND VERTICAL C.G. POSITIONS NOT EXCEEDING VALUES SHOWN.
- THIS CALCULATION WAS PREPARED WITHOUT KNOWLEDGE OF ANY SITE CONDITION. COMPATIBILITY FOR USE WITH A SITE SHALL BE EVALUATED BY THE STRUCTURAL ENGINEER OF RECORD OF THE INSTALLATION (SEOR). USE REQUIRES APPROVAL BY THE SEOR.
- STRUCTURAL ENGINEER OF RECORD FOR THE INSTALLATION SHALL VERIFY ALL CONDITIONS, EVALUATE INTERACTION WITH ADJACENT EQUIPMENT AND ANCHORS, AND PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



### PATTERSON-KELLEY

### STORM 650/800/1000 COMMERCIAL BOILERS

DES. **J. ROBERSON**

JOB NO. **11-2506**

DATE **5/23/25**


SHEET

# 2

OF **2** SHEETS

SEISMIC ANCHORAGE

SLAB ON GRADE



SIDE ELEVATION

MODEL NUMBER	TOTAL WEIGHT (lb.)	$\bar{Y}$ (in.)	"A" (in.)	"B" (in.)	"C" (in.)	"D" (in.)	$T_u$ (lb.)	$V_u$ (lb.)
ST650	625	19.01	9.76	8.39	25.06	18.09	793	480
ST800	660	18.93	9.81	8.34	24.41	18.74	814	497
* ST1000	705	18.84	9.88	8.27	23.19	19.96	827	515

**LOADS:**

WEIGHT ( $W_p$ ) = 705 LB  
 HORIZONTAL FORCE ( $E_{mh}$ ) =  $2.07 W_p$  = 1459 LB  
 VERTICAL FORCE ( $E_v$ ) =  $0.46 W_p$  = 324 LB

ANCHOR SPEC: 5/8"φ HILTI KB-TZ2 (SS); ( $h_{ef}$  = 3.25")  
 SPACING = 12" MIN  
 EDGE DISTANCE = 32" MIN;  
 $\phi T$  =  $0.75 \phi N_n$  = 3285 LB/ANCHOR (TENSION)  
 $\phi V$  =  $\phi V_n$  = 6668 LB/ANCHOR (SHEAR)

**ANCHOR FORCES:**

TENSION (T)

$$T_u \text{ MAXIMUM} = \left[ \frac{1459\#(18.84\")(9.88\"){}}{1 \text{ BOLT } (43.15\")(18.15\")} \times (0.3) \right] + \frac{1459\#(18.84\")(23.19\"){}}{1 \text{ BOLT } (18.15\")(43.15\")} - \frac{(705\#(0.9) - 324\#)(9.88\")(23.19\"){}}{1 \text{ BOLT } (18.15\")(43.15\")} = 827 \text{ LB/BOLT (MAX)}$$

( HORIZ - FRONT TO BACK )                      ( HORIZ - SIDE TO SIDE )                      ( WEIGHT(0.9) -  $E_v$  )

SHEAR (V)

$$V_u \text{ MAXIMUM} = \left[ \frac{1459\#(23.19\"){}}{2 \text{ BOLTS } (43.15\")} \times (0.3) \right] + \frac{1459\#(9.88\"){}}{2 \text{ BOLTS } (18.15\")} = 515 \text{ LB/BOLT (MAX)}$$

**INTERACTION:**

$$\left( \frac{T_u}{\phi T} \right) + \left( \frac{V_u}{\phi V} \right) \leq 1.2 \left( \frac{827}{3285} \right) + \left( \frac{515}{6668} \right) = 0.33 \leq 1.2 \therefore \text{O.K.}$$

### PATTERSON-KELLEY

### STORM 650/800/1000 COMMERCIAL BOILERS

DES. J. ROBERSON

JOB NO. 11-2506

DATE 5/23/25


SHEET

1

OF 2 SHEETS

SEISMIC ANCHORAGE

UPPER FLOOR



**NOTES:**

- FORCES ARE DETERMINED PER 2022 CALIFORNIA BUILDING CODE AND ASCE 7-16. STRENGTH DESIGN IS USED. (EXAMPLE:  $S_{ds} = 2.30$ ,  $a_p = 1.0$ ,  $I_p = 1.5$ ,  $R_p = 2.5$ ,  $z/h \leq 1$ )

HORIZONTAL FORCE ( $E_h$ ) =  $1.66 W_p$

VERTICAL FORCE ( $E_v$ ) =  $0.46 W_p$

- THIS CALCULATION ENCOMPASSES WEIGHTS AND VERTICAL C.G. POSITIONS NOT EXCEEDING VALUES SHOWN.
- THIS CALCULATION WAS PREPARED WITHOUT KNOWLEDGE OF ANY SITE CONDITION. COMPATIBILITY FOR USE WITH A SITE SHALL BE EVALUATED BY THE STRUCTURAL ENGINEER OF RECORD OF THE INSTALLATION (SEOR). USE REQUIRES APPROVAL BY THE SEOR.
- STRUCTURAL ENGINEER OF RECORD FOR THE INSTALLATION SHALL VERIFY ALL CONDITIONS, EVALUATE INTERACTION WITH ADJACENT EQUIPMENT AND ANCHORS, AND PROVIDE SUPPORT STRUCTURE DESIGNED TO SUPPORT WEIGHTS AND FORCES SHOWN IN COMBINATION WITH ALL OTHER LOADS THAT MAY BE PRESENT.



### PATTERSON-KELLEY

### STORM 650/800/1000 COMMERCIAL BOILERS

DES. J. ROBERSON

JOB NO. 11-2506

DATE 5/23/25


SHEET

2

OF 2 SHEETS

SEISMIC ANCHORAGE

UPPER FLOOR



SIDE ELEVATION

MODEL NUMBER	TOTAL WEIGHT (lb.)	$\bar{Y}$ (in.)	"A" (in.)	"B" (in.)	"C" (in.)	"D" (in.)	T <sub>u</sub> (lb.)	V <sub>u</sub> (lb.)
ST650	625	1901	9.76	8.39	25.06	18.09	621	385
ST800	660	18.93	9.81	8.34	24.41	18.74	637	399
* ST1000	705	18.84	9.88	8.27	23.19	19.96	646	413

LOADS:

WEIGHT (W<sub>p</sub>) = 705 LB  
 HORIZONTAL FORCE (E<sub>h</sub>) = 1.66 W<sub>p</sub> = 1170 LB  
 VERTICAL FORCE (E<sub>v</sub>) = 0.46 W<sub>p</sub> = 324 LB

ANCHOR SPECS: 5/8"φ (A193-B8) SS THREADED ROD

φT = 12,940 LB/BOLT (TENSION)  
 φV = 4780 LB/BOLT (SHEAR)

ANCHOR FORCES:

TENSION (T)

$$T_u \text{ MAXIMUM} = \left[ \frac{1170\#(18.84\")(8.39\"){}}{1 \text{ BOLT } (43.15\")(18.15\")} \times (0.3) \right] + \frac{1170\#(18.84\")(23.19\"){}}{1 \text{ BOLT } (18.15\")(43.15\")} - \frac{(705\#(0.9) - 324\#)(8.39\")(23.19\"){}}{1 \text{ BOLT } (18.15\")(43.15\")} = 646 \text{ LB/BOLT (MAX)}$$

( HORIZ - FRONT TO BACK )                      ( HORIZ - SIDE TO SIDE )                      ( WEIGHT(0.9) - E<sub>v</sub> )

SHEAR (V)

$$V_u \text{ MAXIMUM} = \left[ \frac{1170\#(9.88\"){}}{2 \text{ BOLTS } (18.15\")} \times (0.3) \right] + \frac{1170\#(23.19\"){}}{2 \text{ BOLTS } (43.15\")} = 413 \text{ LB/BOLT (MAX)}$$